



Swan Roof Consulting Inc.
Suite 107, 5-8720 Macleod Trail SE
Calgary, AB, T2H 0M4
T: 403.288.5044 F: 403.288.5021
E: info@swanrc.ca

Steep-Slope Roofing Quality Assurance Inspection Report

Report No. 7 Report Type: Pre-Start Initial Interim Final Post Final Report Date: June 27, 2012
Inspector File No: 12-483 New Reroof

| | | | |
|---------------------|----------------------------|------------------|-----|
| | | Area in Squares: | 300 |
| Project Name: | Chaparral Estates | | |
| Address: | Chaparral Ridge Terrace SE | | |
| City: | Calgary, AB | | |
| Roofing Contractor: | Royal Roofing | | |

DESCRIPTION OF OBSERVED ROOFING OPERATIONS


| | | | |
|-------------------------------|------------------------|------------|-------|
| Date of Site Visit: | June 27, 2012 | Time: | PM |
| Roof/Building Section: | 74/76/78/80—6466/68/70 | | |
| Current Application Location: | 64/66/68/70 | | |
| Weather Conditions: | Sunny | Temp.: | 18 °C |
| Onsite Journeyman/Foreman | Burhan | Crew Size: | 5 |

Roof Observations:

1. Roofing contractor on site at time of observation.
2. Previous day's Application: **74/76/78/80**
 - a. New roofing system appears to have been applied with the exception of the ridge vents and ridge caps, hip caps, and the metal wall flashings.
3. Building: **64/66/68/70-20SQ**
 - a. Roofing contractor has applied the 28 gauge pre painted metal drip edge along the eaves and rakes.
 - b. Roofing contractor has applied 36" of Lastobond 195 eave protector along the eaves. The eave protector has been run parallel with the eaves.
 - c. Roofing contractor has applied the Titanium UDL synthetic underlayment felt all over the roof field and under the valleys. The underlayment felt has been run parallel with the eaves.
 - d. Roofing contractor is in the process of applying the BP Starter Strips along the eaves and rakes.
 - e. Roofing contractor has applied the 28 gauge pre-painted W metal valleys. The synthetic underlayment felt has been applied under the valleys.
 - f. Roofing contractor is in the process of applying the Malarky Legacy SBS Black Oak shingles-mechanically fastened.

Report Distribution:

Owner: andrew.prairie@telus.net;
tchenko@shaw.ca
Roofing Contractor: ilia.pengu@gmail.com

| | | | |
|---|-------------------|--|---|
| Attending Inspector Name: Signature: | Albert Gashi |  | <input checked="" type="checkbox"/> Apprentice or <input type="checkbox"/> ARCA accepted |
| Report Reviewed by: Signature: | Bill Elliott, RRO |  | |