



Swan Roof Consulting Inc.
 Suite 107, 5-8720 Macleod Trail SE
 Calgary, AB, T2H 0M4
 T: 403.288.5044 F: 403.288.5021
 E: info@swanrc.ca

Low-Slope Roofing Quality Assurance Inspection Report

Report No. 34 **Report Type:** Initial Interim Final Post Final **Report Date:** 8 August 2012

Inspector File No: _____ New Reroof

	Area in Squares: 676
Project Name:	Chaparral Estates
Address:	Chaparral Ridge Terrace SE
City:	Calgary, AB
Roofing Contractor:	Royal Roofing

DESCRIPTION OF OBSERVED ROOFING OPERATIONS			
Date of Site Visit:	8 August 2012	Time:	AM
Roof/Building Section:	Block 89 to 99		
Current Application Location:	Block 89 to 99		
Weather Conditions:	overcast	Temp.:	18°c
Onsite Journeyman/Foreman	Burhan	Crew Size:	6

Roof Observations:

1. Met on roof with Burhan, Royal Roofing
2. Crew is tearing off east ½ of building, deck is sound as seen.
3. Discussed spec and other buildings.
4. Note: There are 2 blocks not yet started, this block which was started today except for first floor rear bays which were started and covered with self adhesive underlay yesterday.
5. Note: There are 3 blocks that are completed according to Burhan.
6. Note: Balance of complex is roofed except for hip and ridge Alaskan shingles which have been on back order. Burhan indicates he may receive delivery by end of week.
7. Per Burhan 11 buildings, 3 complete, 5 need hip/ridge , 1 started (this one) and 2 not started.

Report Distribution:

Owner: andrew.prairie@telus.net; tchenko@shaw.ca;
 Roofing Contractor: ilia.pengu@gmail.com

Attending Inspector Name: Signature:	Lee Sonmor		<input type="checkbox"/> Apprentice or <input checked="" type="checkbox"/> ARCA Accepted
Report Reviewed by: Signature:	Bill Elliott, RRO		