

Swan Roof Consulting Inc. Suite 107, 5-8720 Macleod Trail SE Calgary, AB, T2H OM4

T: 403.288.5044 F: 403.288.5021

E: info@swanrc.ca

Steep-Slope Roofing Quality Assurance Inspection Report

Report No. Report 7	「ype: Pre-S	Start Initial	Interim	Final	Post Final		Report Date: 13 August 2012	
Inspector File No: 12-483 New ☐ Reroof ☒								
				Area in Squares:		300		300
Project Name: Chaparral Estates								
Address:	Chaparral Ridge Terrace SE							
City:	Calgary, AB							
Roofing Contractor:	Royal Roofing							
DESCRIPTION OF OBSERVED ROOFING OPERATIONS Date of Site Visit: 13 August 12 Time: PM								
Roof/Building Section:	Block 82-88							1
Current Application Location:		Main						
Weather Conditions:		sunny				Temp.: 25 °C		
Onsite Journeyman/Foren	nan	Burhan				Crew S	ize:	4
 Crew is tearing main roof rear on this block. Discussed extent of work today based on upcoming weather forecast. Crew intend to install eave protection and underlay to rear where tear off is done. (no shingles) Contractor has received hip/ridge shingles and will be installing this building complete prior to starting next building. Discussion with Burhan regarding adjacent building block 89-99 that is reported complete. Ridge Crest vented ridge and Alaskan hip/ridge are completed on this building. Walk around of grounds at building noted that clean-up is done, however additional check should be completed to ensure all small bits are cleaned up. Discussed detail at hip to eave transition on lower aprons, contractor will install self-adhesive Report Distribution: Owner: andrew.prairie@telus.net; chenko@shaw.ca; ilia.pengu@gmail.com								
Attending Inspector Name: Signature:	Lee So	onmor		v	hun		-	oprentice or CA accepted
Report Reviewed by: Signature:	Bill Elli	iott, RRO		Bi). <i>Elliot</i> t	4		